



Upgrade Existing SCWD-SqCWD Intertie (/initiative/4Xws/upgrade-existing-scwd-sqcwd-intertie)

Expand existing 6" SCWD/SqCWD intertie now by increasing pipe diameter to 18" for a short distance; get emergency or temporary permit; install a bi-directional variable-speed low-pressure inline pump to control water transfer capacity of at least 2000 AFY; capture an extra 300 to 500 AFY this winter. Re-apply for rights each winter during tide-over.

Submitted by Jerry Paul

Comments

Jan Karwin 2w ago

PRO

This proposal is worthy of further research and evaluation by the panel of experts.